

The following is an amendment to our 2012 Consumer Confidence Report previously distributed in the White Mountain Independent on July 20, 2012.

Consumer Confidence Report

I. Public Water System (PWS) Information

PWS Name:	Town Of Springerville		
PWS ID#	AZ04-01013		
Owner / Operator	Tim Rasmussen / Robert Pena		
Telephone #	928-333-5016	928-333-3268	E-Mail trasmussen@springervilleaz.gov

IX. Water Quality Data

Microbiological	Violation Y or N	Number of Samples Present OR Highest Level Detected	Absent (A) or Present (P) OR Range of All Samples (L-H)	MCL	MCLG	Sample Month & Year	Likely Source of Contamination
Total Coliform Bacteria (System takes ≥ 40 monthly samples) 5% of monthly samples are positive; (System takes ≤ 40 monthly samples) 1 positive monthly sample	Y	1 of 32	P	0	0	9/4/12	Naturally Present in Environment
Fecal coliform and E. Coli (TC Rule)	N		A	0	0	9/4/12	Human and animal fecal waste
Lead & Copper	Violation Y or N	90th Percentile AND Number of Samples Over the AL	Range of All Samples (L-H)	AL	ALG	Sample Month & Year	Likely Source of Contamination
Copper (ppm)	N	90th Percentile =	<0.020-0.27	AL = 1.3	ALG = 1.3	8/7/12	Corrosion of household plumbing systems; erosion of natural deposits
Lead (ppb)	N	90th Percentile =	<0.0010-0.0039	AL = 15	0	8/7/12	Corrosion of household plumbing systems; erosion of natural deposits
Radionuclides	Violation Y or N	Running Annual Average (RAA) OR Highest Level Detected	Range of All Samples (L-H)	MCL	MCLG	Sample Month & Year	Likely Source of Contamination
Beta / photon emitters (mrem/yr)				4	0		Decay of natural and man-made deposits
Alpha emitters (pCi/L)	N	12.18	5.9 - 22 pci / L	15	0	9/1/10	Erosion of natural deposits
Combined Radium 226 & 228 (pCi/L)	N	4.23	.5 - 8.2 pci / L	5	0	9-1-2010 12-1-2010	Erosion of natural deposits
Inorganic Chemicals (IOC)	Violation Y or N	Running Annual Average (RAA) OR Highest Level Detected	Range of All Samples (L-H)	MCL	MCLG	Sample Month & Year	Likely Source of Contamination
Barium (ppm)	N	.25 ppm	.19 - .25	2	2	9/1/10	Discharge of drilling wastes, discharge from metal refineries; Erosion of natural deposits
Flouride (ppm)	N	72 ppm	.48 - 72ppm	4	4	9/1/10	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Nitrate (ppm)	N		20.1 - 0.43	10	10	8/9/12	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits

XII. Violations

Type/ Description	Compliance Period	Corrective Actions Taken by PWS
TOTAL COLIFORM	9/1/2012	Flush, Chlorinate, Re-sample